

Emission Test Certificate

Tuesday October 26th, 2021

Supplier: A J Bates Limited (205 Station Road, Penrose, Auckland 1061, New Zealand)

Sample Description: PureCoat LPM

Date Tested: October 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (7 days exposure):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">PureCoat LPM</p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.011 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.018 mg/m²/hr</p>
<p align="center"><i>We hereby certify that PureCoat LPM complies with requirements of Green Star Design & As Built – Green Star Interiors, Green Building Council of Australia.</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Tuan Duong
B Eng. (Chem.)
Senior Consultant

V2110014