

# Emission Test Certificate

Tuesday October 26<sup>th</sup>, 2021

Supplier: A J Bates Limited (205 Station Road, Penrose, Auckland 1061, New Zealand)

Sample Description: PureCoat

Date Tested: October 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (7 days exposure):**

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>PureCoat</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.046 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate limit: ≤0.100 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: 0.027 mg/m<sup>2</sup>/hr</p>
<p align="center"><b><i>We hereby certify that PureCoat complies with requirements of Green Star Design &amp; As Built – Green Star Interiors, Green Building Council of Australia.</i></b></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Tuan Duong  
B Eng. (Chem.)  
Senior Consultant

**V2110014**