

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

Group Number Assessment

(In accordance with New Zealand Building Code Verification Method C/VM2 Appendix A)

This is to confirm that the product as described below has been tested by AWTA Product Testing.

Testing was performed in accordance with ISO 5660.1-2015 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

Test Sponsor : AJ Bates
205 Station Road
Penrose Auckland 1061 New Zealand
New Zealand

Test Number : 21-005142
Issue Date : 18/10/2021
Print Date : 18/10/2021

Sponsor Product Clients Ref : "Pure Coat Low Pressure Laminate"
Laminated MDF Panel
Colour : White wash oak
End Use : Internal Use- Kitchen, Laundry, Bathroom Cabinetry
Nominal Composition : MDF Core, low pressure melamine decorative paper both sides
Nominal Mass per Unit Area/Density : 770kg/m³
Nominal Thickness : 18mm

Product Group Number Classification : 3

Average Specific Extinction Area : 29.2 m²/kg



Fiona McDonald
Testing Technologist

54714

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.